



Notes :-

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. THE MINIMUM DEPTH OF INSTALLATION SHALL BE DN+50 TO INVERT BENEATH SUBFORMATION LEVEL OR 600mm TO THE INVERT BENEATH FORMATION LEVEL. WHERE THERE IS NO CAPPING LAYER THE DRAINS SHOULD BE LAID TO THE LOWER OF THOSE TWO DEPTHS.
3. ROUNDDING OCCURS OVER A 1500mm LENGTH 750mm EITHER SIDE OF INTERSECTION BETWEEN VERGE AND BATTER.
4. SET BACK REQUIREMENTS IN ACCORDANCE WITH DN-REQ-03034.
5. REFER TO CC-SCD-00520 FOR TRENCH AND BEDDING DETAILS FOR FILTER DRAIN.
6. PERMITTED VERGE-SIDE EDGE DRAINAGE OPTIONS ARE INDICATED IN DN-DNG-03022.
7. THE MAXIMUM DROP SHALL BE IN ACCORDANCE WITH CC-SCD-00701.