



- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES EXCEPT WHERE STATED.
  2. CHAMBER WALLS AND COVER SLAB TO BE CONSTRUCTED IN PRECAST CONCRETE TO BS 5911-3 AND IS EN 1917.
  3. FOR INVERT DETAILS, NUMBER OF BRANCHES, DETAILS OF PIPES AND TYPE OF COVER AND FRAME SEE THE DRAINAGE SCHEDULE.
  4. MORTAR TO BE TO CLAUSE 507.17
  5. SAFETY CHAIN REQUIRED WHERE PIPE IS GREATER THAN 600 DIAMETER. SEE DRAWING No RCD/500/11 FOR DETAILS OF SAFETY CHAIN AND HANDHOLDS.
  6. TOE HOLD REQUIRED WHERE PIPE IS 525 DIAMETER OR GREATER. SEE DRAWING No RCD/500/11 FOR DETAILS.

NOT TO SCALE

P5	04/11
P4	12/10
P3	01/09
Issue	Date