



- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES.
 2. PLAN AND SECTION A-A INDICATE OUTLET WITH TRIPLE GRATING INSTALLATION AND ASSOCIATED CHAMBERS. DETAIL CAN BE MODIFIED FOR TWIN AND SINGLE GRATING INSTALLATION OR FOR OFF-LINE OUTLETS TO TRAPEZOIDAL OR TRIANGULAR S.W. CHANNEL. ASSOCIATED DRAINS AND PIPEWORK SHALL BE AS DETAILED ON THE DRAWINGS AND SCHEDULES. APRON SLAB ON PLAN AND SECTION B-B SHOWN TO SUIT VERGE INSTALLATION. SLAB WIDTH AND PROFILE DIFFERS WHEN USED IN CENTRAL RESERVE LOCATION.
 3. CHAMBER GRATINGS AS SPECIFIED IN CHAMBERS SCHEDULE TO SUIT CROSS SECTION OF APRON. GRATING FRAMES TO BE BEDDED ON MORTAR AND SECURELY FIXED TO REBATES FORMED IN CONCRETE APRON BY APPROVED MECHANICAL MEANS. FRAME TO BE OTHERWISE BEDDED ON EPOXY RESIN MORTAR.
 4. CHAMBER BENEATH APRON SLAB TO BE IN ACCORDANCE WITH PRECAST CATCHPIT DETAILS. SEE CC-SCD-00509 AND CC-SCD-00515.
 5. A TRANSVERSE JOINT SHALL BE FORMED AT EACH END OF THE APRON SLAB IN ACCORDANCE WITH CC-SPW-01000. TRANSVERSE JOINTS SHALL NOT BE PERMITTED WITHIN THE APRON SLAB. NO JOINTS SHALL BE PERMITTED WITHIN ADJACENT LENGTHS OF CONCRETE PAVEMENT SLABS. NECESSARY JOINTS IN SUCH SLABS SHALL BE SPACED ACCORDINGLY.
 6. APRON SLAB AND ASSOCIATED DIMENSION H TO BE DESIGNED TO WITHSTAND THE ACCIDENTAL WHEEL LOADING DEFINED IN IS EN 1991 -2 + NA CLAUSE 4.7.3.1. CONCRETE TO APRON SLAB SHALL COMPLY WITH CC-SPW-01100. PLAIN CONCRETE SHALL BE A DESIGNED CONCRETE, STRENGTH CLASS C 28/35 TO IS EN 206-1. REINFORCED CONCRETE SHALL BE STRENGTH CLASS C 32/40 TO CC-SPW-01000 CLAUSE 1001.
 7. TRANSITION/TERMINAL RAMP TO BE FORMED AS AN INTEGRAL PART OF THE APRON SLAB.
 8. OVER EXCAVATION FOR MAIN CHAMBER BENEATH SUBSIDIARY CHAMBERS TO BE BACKFILLED WITH ST1 CONCRETE TO CC-SPW-02600 CLAUSE 2602.





SECTION A-A



SECTION B-B

NOT TO SCALE

 <p>Bonneagar Iompair Éireann Transport Infrastructure Ireland</p>	 <p>Construction & Commissioning</p>	<p>PUBLICATION TITLE</p> <p>IN-LINE OUTLET TO TRAPEZOIDAL SURFACE WATER CHANNEL</p>								
	<p>STREAM</p> <p>STANDARD CONSTRUCTION DETAILS (SCD)</p>	<p>HISTORICAL REFERENCE</p> <p>RCD/500/27</p>	<p>DOCUMENTATION SET</p> <p>STANDARDS</p>	<p>PUBLICATION DATE</p> <p>FEBRUARY 2024</p>	<p>PUBLICATION NUMBER</p> <table border="1"> <tr> <td>ACTIVITY</td> <td>STREAM</td> <td>DRAWING NUMBER</td> </tr> <tr> <td>CC</td> <td>SCD</td> <td>00527</td> </tr> </table>	ACTIVITY	STREAM	DRAWING NUMBER	CC	SCD
ACTIVITY	STREAM	DRAWING NUMBER								
CC	SCD	00527								