



CONTRACTION JOINT - WITH SAWN GROOVE

DOWEL BAR - MIN DIMS		
SLAB THICKNESS DIMENSION 'D'	DIMENSION 'B'	DIMENSION 'C'
150 TO 239	20	400
240 AND OVER	25	600

- NOTES:-
1. ALL DIMENSIONS ARE IN MILLIMETRES.
 2. THE DOWEL BARS SHALL BE PLACED AT 300 CENTRES. THIS SPACING SHALL BE VARIED WHERE NECESSARY SO THAT NO DOWEL BAR IS WITHIN 150 OF A JOINT PARALLEL TO THE BARS.
 3. WHEN CONCRETE PAVEMENT IS OVERLAID WITH 40mm TO 180mm THICK BITUMINOUS SURFACING, THE OVERLAY SHALL BE SAW-CUT AND SEALED AT THE CONCRETE PAVEMENT JOINT IN ACCORDANCE WITH CC-SPW-00700.
 4. DOWEL BARS SHALL CONFORM TO CC-SPW-01000.



PUBLICATION TITLE
**CONCRETE PAVEMENT
CONTRACTION JOINTS**

ACTIVITY STANDARD CONSTRUCTION DETAILS (SCD)	HISTORICAL REFERENCE RCD/1000/3	DOCUMENTATION SET STANDARDS	PUBLICATION DATE NOVEMBER 2010	PUBLICATION NUMBER ACTIVITY: CC STREAM: SCD DRAWING NUMBER: 01003
--	---	---------------------------------------	--	---