



NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
2. THE OVERALL DIMENSIONS OF THE OPENING MAY VARY IN ACCORDANCE WITH THE TYPE OF GULLY GRATING USED.
3. CONCRETE SURROUND TO BE STRENGTH CLASS C32/40.
4. NORMAL TRANSVERSE REINFORCEMENT NEAR OPENING TO BE STRENGTHENED BY ADDITIONAL Ø8 BARS PLACED CENTRALLY BETWEEN THE TRANSVERSE BARS.
5. REINFORCEMENT SHALL CONFORM TO CLAUSE 1008.
6. THE Ø12 STIRRUP SHALL BE CUT AND BENT TO SUCH DIMENSIONS AS ALLOW IT TO BE LOCATED CENTRALLY WITHIN THE SURROUND. 450 OVERLAP SHALL BE PROVIDED IN CLOSING THE STIRRUP.
7. FOR GULLY DETAILS SEE RCD/500/14 AND 15