



TACTILE PAVING  
TACTILE PAVING ON APPROACH TO PEDESTRIAN CROSSING ARE REQUIRED ON CYCLEWAYS AND FOOTWAYS

- NOTES :-
1. A RAISED LIP OF 25mm SHOULD BE USED FOR VEHICULAR ENTRANCES.
  2. A RAISED LIP OF 0-6mm SHOULD BE USED FOR PEDESTRIAN CROSSING.
  3. REFER TO CC-SCD-01109 FOR PRECAST KERB DIMENSIONS.
  4. REFER TO CC-SCD-01102 FOR INSITU CONCRETE KERB DIMENSIONS.
  5. TACTILE PAVING IS TO BE PROVIDED AT ALL PEDESTRIAN CROSSINGS, ADVICE ON THE EXACT LOCATION AND DIMENSIONS CAN BE FOUND FROM THE UK DEPARTMENT FOR TRANSPORT, MOBILITY INCLUSION UNIT DOCUMENT, "GUIDANCE ON THE USE OF TACTILE PAVING SURFACE".
  6. ALL DIMENSIONS ARE IN MILLIMETRES.
  7. TACTILE PAVING TO BE LAID ON A MINIMUM 30mm / MAXIMUM 70mm COMPACTED THICKNESS OF SEMI-DRY CONCRETE CONTAINING FORTA-FIBRE POLYPROPYLENE FIBRES OR OTHER APPROVED EQUIVALENT FIBRE. REINFORCEMENT AT A RATE OF 0.9 kg/m<sup>3</sup>. THE COMPRESSIVE STRENGTH OF THE BEDDING SHALL NOT BE LESS THAN 35 N/sq mm.

VEHICULAR ACCESS:  
RAMP CONSTRUCTION FROM GRADE C30 CONCRETE 150mm THICK WITH A393 MESH REINFORCED TOP AND BOTTOM. SURFACE OF RAMP TO BE BRUSHED TOP FROM 'NON-SLIP' FINISH.

PEDESTRIAN CROSSINGS:  
TACTILE PAVING TO BE PROVIDED TO GIVE GUIDANCE TO VISUALLY IMPAIRED PEDESTRIANS.

 Bonneagar Iompair Éireann Transport Infrastructure Ireland	ACTIVITY  Construction & Commissioning	PUBLICATION TITLE KERBS, FOOTWAYS AND PAVED AREAS DROPPED KERB RAMP		
	STREAM STANDARD CONSTRUCTION DETAILS (SCD)	HISTORICAL REFERENCE RCD/1100/3	DOCUMENTATION SET STANDARDS	PUBLICATION DATE MARCH 2020