



NOTES:

1. ELECTRICAL DETAIL SHOWN ON DRAWING ARE INDICATIVE ROADSIDE EQUIPMENT CABINET HEATER CONNECTION ONLY.
2. THE ELECTRICAL WORKS ASSOCIATED WITH THE CABINET HEATER SHALL BE IN ACCORDANCE WITH THE NATIONAL RULES FOR ELECTRICAL INSTALLATIONS BY THE ELECTRO TECHNICAL COUNCIL OF IRELAND.
3. THE CONTRACTOR SHALL CONNECT THE HEATER TO A DEDICATED MCB LOCATED IN THE CABINET'S POWER DISTRIBUTION UNIT (PDU) AND SHALL CONNECT THE THERMOSTAT INTO THE CIRCUIT.
4. THE TYPE AND RATING OF THE PROTECTIVE DEVICES SHALL BE AS DETAILED IN THE ELECTRICAL SPECIFICATION.

NOT TO SCALE

P2	06/15
P1	10/13
Issue	Date