



NOTES:

1. NOT TO SCALE. ALL DIMENSIONS IN MILLIMETRES.
2. THE EMERGENCY ROADSIDE TELEPHONE SHALL BE SET IN A 600x600x200mm ST2 CONCRETE BASE TO CLAUSE 2602.
3. ALL TOPSOIL AND/OR ORGANIC MATERIAL SHALL BE REMOVED. A PLATFORM SHALL BE PREPARED OF SIMILAR STANDARD TO THE SUB-FORMATION OF THE ADJACENT CARRIAGEWAY.
4. ALL PAVING SLABS SHALL BE LAID ON 150mm SUB-BASE COMPLYING WITH CLAUSE 804 AND COMPACTED IN ACCORDANCE WITH CLAUSE 802.
5. HANDRAIL ONLY REQUIRED ON EMBANKMENT OR ADJACENT TO LOCAL HAZARD. HANDRAIL TO BE 1100mm HIGH IN ACCORDANCE WITH BS 6180 AND BS 5395 PART 3. FOOTING TO BE EITHER BOLTED OR ROOTED, AS DETERMINED BY SITE CONDITIONS. REFER TO DRAWINGS RCD/1500/022 & 023.
6. WHERE A FILTER DRAIN IS INCLUDED IN THE VERGE, THE FILTER DRAIN SHALL EXTEND TO THE UNDERSIDE OF THE HARDSTANDING AND BE SEPERATED FROM THE HARDSTANDING BY A GEOTEXTILE MEMBRANE.
7. THE 50mm ϕ DUCT THROUGH THE CONCRETE BASE SHALL BE LEFT 100mm PROUD OF THE SURFACE OF THE BASE.
8. THE DISTANCE FROM THE CENTRE OF THE EMERGENCY TELEPHONE TO THE EDGE OF HARDSHOULDER SHALL NOT BE LESS THAN 1500mm.
9. THE PAVING SLAB/ERT HARDSTANDING AREA SHALL BE LEVEL AND CONTINUOUS WITH THE HARD SHOULDER IN FRONT OF EACH ERT LOCATION. ANY GAPS BETWEEN THE PAVING SLAB/ERT HARDSTANDING AREA SHALL BE FILLED WITH BITUMINOUS MATERIAL.
10. FOR FURTHER TELEPHONE INSTALLATION DETAILS REFER TO:

- DRAWING RCD/1500/061 FOR TELEPHONE INSTALLATION WITH DUCTING/CHAMBER DETAILS
- DRAWING RCD/1500/062 FOR TELEPHONE INSTALLATION BEHIND SAFETY BARRIER
- DRAWING RCD/1500/063 FOR BLISTER SURFACE PAVING SLAB
- MCDRW 1500 SERIES.

TII PUBLICATION NUMBER: CC-SCD-01560